



**Government Of West Bengal
Office Of The Director General
West Bengal Fire & Emergency Services
13D, Mirza Ghalib Street, Kolkata - 16**

Memo no.:FSR/0125186221100502

Date: 24-01-2024

From:
Director
Fire Prevention Wing,
West Bengal Fire & Emergency Services

To: SATYANANDA VIDYANIKETAN
BAGDAH, NORTH 24 PARGANAS, WEST BENGAL, 743232

Sub: Fire Safety Certificate for an existing Two storied School under group occupancy Educational Building in the name & style “SATYANANDA VIDYANIKETAN” at – BAGDAH, MOUZA -36, DAG NO. 1065, KHATIAN NO.-289 NORTH 24 PARGANAS, WEST BENGAL, 743232

This is in reference to your application no. 0125189231100509 dated 18-12-2023 regarding the Fire Safety Certificate for an existing Two storied School under group occupancy Educational Building in the name & style “SATYANANDA VIDYANIKETAN” at – BAGDAH, MOUZA -36, DAG NO. 1065, KHATIAN NO.-289 NORTH 24 PARGANAS, WEST BENGAL, 743232

The performance of the Fire Fighting System as incorporated in the buildings were tested at random and found satisfactorily working condition. In view of the above this office is releasing the Fire Safety Certificate for occupancy of the aforesaid building.

Recommendation:

1. Driveway must be free of any type of obstruction for easy movement of Fire Appliances. No parking will be allowed on the Driveway.
2. The interior finish decoration of the building shall be made with low flame spread material confirming to the I.S. Specification.
3. To eliminate risk of fire hazards, good house-keeping both for inside and outside of the building shall be strictly maintained.
4. Existing Electrical wiring of the whole building shall have to be carefully checked for any wear and tear in them, particularly lines above false ceiling and ducts.
5. Periodical flushing of water in the Hydrants Pipe line shall be made to maintain the Efficiency working performance of the installed FFFS.
6. The notice of Fire Fighting and Evacuation from the building shall be prepared and displayed at all vulnerable of the building.
7. The employees and security staffs shall be conversant with installed Fire Fighting Equipment of the building and to

operate in the event of Fire and Testing.

8. Mock Fire practice and Evacuation Drill shall be performed periodically with participants of all the occupants of the building.

9. Transformer (if any) and switch gear room protection system to be maintained in proper manner & record keeping to be maintained in the fire prevention maintenance register.

10. Electrical ducts shall be sealed vertically and horizontally at each floor level by fire resisting materials.

11. Unauthorized cooking arrangement in any floor of the building using L.P.G., Kerosene etc. shall not be permitted and Fire License shall have to be obtained for storing and processing with L.P.G. and other highly combustible articles.

12. First-Aid Fire Fighting system shall be provided as per I.S. specification.

13. Arrangement shall have to be made for regular checking, testing and maintenance of all the firefighting installation in the building to keep them in perfectly good working condition at all the times.

14. If required the old lines shall have to be replaced with new lines, the cable shall always be laid in M.S. conduit pipes continuously bonded with the earth.

15. The Fire Safety Audit & Electric Audit to be conducted a regular interval and to be recorded in the fire prevention maintenance register.

This Fire Safety Certificate is valid for 3 (Three) year from the date of issue of this letter and have to be renewed within validity period & a certificate is to be obtained from the Director General, West Bengal Fire & Emergency Services.

DIRECTOR
West Bengal Fire & Emergency Services